



NOTES:

1. LAYOUT MUST BE APPROVED BY THE CITY PRIOR TO EXCAVATION IN SODDED AREAS. ARRANGE FOR INSPECTION OF EXCAVATION PRIOR TO PLACEMENT OF AGGREGATE.
2. DO NOT EXCAVATE FOR GRANULAR BASE IN WOODLOTS; PROVIDE MINIMAL GRADING ONLY, PRIOR TO PLACING FILTER FABRIC.
3. COMPACT GRANULAR BASE AND LIMESTONE SCREENINGS TO 85% S.P.D (MIN). AREA USING A DUAL DRUM WALK-BEHIND COMPACTOR (MIN).
4. ENSURE THAT PATHWAY GRADES AND CROSS SLOPE MEET AND MATCH NATURAL DRAINAGE PATTERNS.
5. GALVANIZED CSP CULVERTS TO BE INSTALLED IN ALL LOW AREAS, AS PER LAYOUT AND GRADING PLAN(S), REFER TO DETAIL L510.
6. ASPHALT PAVING IS REQUIRED IF PATHWAY SLOPE IS STEEPER THAN 10%, AS DETERMINED ON A CASE BY CASE ASSESSMENT.
7. ALL MEASUREMENTS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.

